

SSO Notification List												
July 2009												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	7/1/2009	1625 Stonewood Road	21239	Debris	Herring Run	1:30	5:04 PM - 6:34 PM	Sewer Water	450	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	60254
2	7/1/2009	3402 Parkside Drive	21013	Leaking Pipe	Herring Run	120:00	7/1/09 5:00 PM - 5:00 PM 7/6/09	Light Gray Water	7,200	Quick Dry to Patch leak	Tested Site to Ensure Patch was holding	98564
3	7/8/2009	9 North Broadway	21231	Debris	Northwest Harbor	2:46	6:17 PM - 9:03 PM	Sewer Water	Evidence of an Overflow	Relieved M/L Choke with Pressure Jet	Turned over to be CCTV'ed	60451
4	7/8/2009	513 N. Streeper Street	21205	Rags	Inner Harbor	3:51	2:39 PM - 6:30 PM	Paper Debris	Evidence of an Overflow	Relieved M/L Choke with Cleaning Machine	Turned over to be CCTV'ed	60440
5	7/9/2009	222 N. Carrollton Avenue	21217	Rags & Grease	Gwynns Falls	3:00	8:00 AM - 11:00 AM	Heavy Gray Water	540	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	98678
6	7/9/2009	3301 Liberty Heights Avenue	21215	Rags	Gwynns Falls	2:40	7:45 PM - 10:25 PM	Sewer Water	Evidence of an Overflow	Relieved M/L Choke with Cleaning Machine	Turned over to be CCTV'ed	60485
7	7/10/09 - 7/15/2009	4128 Westchester Road	21215	Rags	Gwynns Falls	119	7/10/09 10:00 AM - 9:00 AM 7/15/09	Heavy Gray Water	7,140	Flushed and Repaired M/L	Turned over to be CCTV'ed	98736
8	7/12/2009	1029 N. Central Ave	21202	Rags & Trash	Inner Harbor	0:30	1:30 PM - 2:00 PM	Sewer Water	Evidence of an Overflow	Relieved M/L Choke with Electric Machine	Turned over to be CCTV'ed	98786
9	7/12/2009	6800 Park Heights	21215	Rags	Jones Falls	2:00	8:00 AM - 10:00 AM	Sewer Water	600	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	98780
10	7/12/2009	3306 N. Hilton Street	21216	Rags & Roots	Gwynns Falls	1:00	4:00 PM - 5:00 PM	Heavy Gray Water	120	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	98789
11	7/16/2009	301 Club Road	21210	Roots	Jones Falls	2:55	3:45 PM - 6:40 PM	Sewer Water	350	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	60695
12	7/20/2009	2578 Marbourne Ave	21230	Rags	Patapsco	2:00	11:00 AM - 1:00 PM	Heavy Gray Water	180	Relieved M/L Choke with Electric Machine	Turned over to be CCTV'ed	99047
13	7/21/2009	500 W. University Pkwy	21210	Rags & Roots	Gwynns Falls	19:00	7/21/09 3:00 PM - 10:00 AM 7/22/09	Heavy Gray Water	5,700	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	99053
14	7/24/2009	2400 Harriett Ave	21230	Rags, Roots & Grease	Patapsco	6:00	2:00 PM - 8:00 PM	Heavy Gray Water	3,600	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	99187
15	7/24/2009	2225 Rogene Drive	21209	Rags	Jones Falls	5:56	3:04 PM - 9:00 PM	Sewer Water, Paper Debris	2,492	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	60907
								TOTAL	28,372			